



Cherpulassery Municipality

Pincode: 679503 GST: 32AAALC2656G1ZK

Phone number 0466-2282238 Email: seccpymun@gmail.com

<https://cherpulasserymunicipality.lgokerala.gov.in>

Certificate number : 3910472-2026

Date : 02-06-2026

SANITARY CERTIFICATE

I have inspected KUTTIKKODE ENGLISH MEDIUM CENTRAL SCHOOL (K.E.M.C.S)Kuttikkode, Thrikkadeeri (po) on 30/05/2026. The classrooms are spacious,properly ventilated and lighted.The building and surroundings are kept clean Adequate number of latrines and urinals are provided and maintained well The sanitary condition of the school is satisfactory

Signature Not Verified
Digitally signed by Mahoj Kumar C
Date: 2026.06.02 11:18:17 IST
Reason: KSEBART

കുടുംബശ്രീ നഗരസഭ

ENVIRONMENT LABORATORY
Approved by: Kerala State Pollution Control Board
Approval No.: PCB/LAB/02/2005

No. IRTC/311/ENVL/ WS260513/26

WATER QUALITY ANALYSIS REPORT

Name and Address of the Client	Location/ Code	Date of receipt	Source of sample
Manager KEMCS Kuttikode, Cherupulassery	Not Given	04/05/2026	Bore Well
		Sample No	Date of report
		WS260513	15/05/2026


Sl. No	Parameter	Unit	Test Result	Acceptable Limit For Drinking Water as per IS 10500:2012	Test Method
01	pH @ 25°C	-	6.0	6.5-8.5	IS 3025(Part 11):2022
02	EC @ 25°C	µs/cm	1050	-	IS 3025(Part 14):2013
03	TDS	ppm	590	500 (max)	IS 3025(Part 16):2023
04	Turbidity	NTU	1.4	05 (max)	IS 3025(Part 10):2023
05	Alkalinity as mg CaCO ₃ / L	mg/L	80	200 (max)	IS 3025(Part 23):2023
06	Chloride	mg/L	100	250 (max)	IS 3025(Part 32):1988
07	Total Hardness as mg CaCO ₃ / L	mg/L	530	200 (max)	IS 3025(Part 21):2009
08	Calcium	mg/L	150	75 (max)	IS 3025(Part 40):1991
09	Magnesium	mg/L	40	30 (max)	IS 3025(Part 46):2023
10	Fluoride	mg/L	1.0	1.0 (max)	IS 3025(Part 60):2008
11	Total Iron	mg/L	0.01	0.3 (max)	IS 3025(Part 14):2013
12	Sulphate	mg/L	89	150 (max)	IS 3025(Part 24):2022
13	Nitrate	mg/L	0.1	45 (max)	APHA, AWWA, WEF 2017
14	Total Coliform	MPN/100ml	Absent	Shall not be detected /100ml	APHA, AWWA, WEF 2017
15	E.coli	-	Absent	Shall not be detected /100ml	APHA, AWWA, WEF 2017


- EC - Electrical Conductivity, TDS - Total Dissolved Solids, NTU-Nephelometric turbidity unit, MPN- Most Probable Number.
- µs- Micro siemens, BIS-Bureau of Indian Standards, mg/L- milligram per liter.
- Coliform & E. coli should not be present in 100 ml of sample

Disclaimer: The sample was taken and brought to the lab by the person with name and address mentioned above and not by IRTC.


Babitha K B
Chemist




Shiona Sunil
Microbiologist


A. N. SIVADAS
Head, Environment Laboratory
Integrated Rural Technology Centre
Mundur, Palakkad, Kerala-678 592